

Application of Methods and Discussion of the Results about the Ageing in Probabilistic Safety Assessment

Čepin Marko

“Jožef Stefan” Institute

Jamova 39, SI-1000 Ljubljana, Slovenia

marko.cepin@ijs.si

ABSTRACT

Probabilistic safety assessment is a standardised tool for assessment of safety of nuclear power plants. It is more and more included in the risk-informed decision-making. The objective of the paper is to analyze theoretical models of ageing and to provide examples of their application, which would represent the standpoint for an upgrade of current probabilistic safety assessment with the direct inclusion of ageing. The paper presents theoretical models of ageing and practical examples, which show, how the current models can be upgraded in sense to directly include the effects of ageing into the models of probabilistic safety assessment. The most important problem is the lack of data about the effects of ageing, which would suit to the well developed and detailed models of ageing. In addition to theoretical models of ageing and to practical examples of their application in the probabilistic safety assessment, this paper brings forward findings and judgments, which does not support a direct inclusion of ageing into the existing probabilistic safety assessment. Namely, ageing has already been included in the models, when the constant failure rate is assumed. It only isn't separated from other causes of components and systems faults. Another fact is that the effects of ageing may contribute to the models and results of probabilistic safety assessment less than other important features, which are candidates for improvement of the existing probabilistic safety assessment. From this, it can be concluded, that it is reasonable, that the models and the results of probabilistic safety assessment are firstly improved considering the suggested features and then the inclusion of ageing is considered.

1 INTRODUCTION

Ageing is a process, where the properties of systems and processes may degrade through the time and age.

Probabilistic safety assessment is a standardised tool for assessment of safety of nuclear power plants, references from [1] to [29]. It is more and more included in the risk-informed decision-making.

The objective of the paper is to analyze theoretical models of ageing and to provide examples of their application, which would represent the standpoint for an upgrade of current probabilistic safety assessment with the direct inclusion of ageing.

2 STATE –OF-THE-ART

Many activities are connected with consideration of ageing and lifetime of the equipment. Models and analysis include a wide variety of applications, which are included in references from [30] to [69].

Consideration of ageing in probabilistic safety assessment is dealt with in the references from [70] to [100]. The most important problem is the lack of data about effects of ageing, which would suit to the well developed and detailed models of ageing.

Selected studies have shown the risk and reliability implications of aging [95], [96], [97]. Same authors believe that the contribution of aging to the risk measures may be assessed as very small or almost negligible considering the uncertainty of models, data and analysis results [98], [100]. Others indicate, that aging of passive components may be necessary for assessment of safety [77].

3 METHODS

Many mathematical methods for consideration of ageing exist. They include mathematical formulations of parameters, for which it is very difficult to get appropriate data, which could make the methods widely applicable.

Selected methods for consideration of ageing are presented in the following sections.

3.1 Basic methods for modelling of ageing

Weibull method, linear method and exponential method are presented.

3.1.1 Weibull method

This method represents the failure rate of equipment with a function, where the failure rate is changed with age of equipment from constant failure rate before the threshold age to the Weibull increasing failure rate after the threshold age.

The basic mathematical formulation of the method is presented in the equation below.

$$\begin{aligned} \lambda(w) &= \lambda_0 & \forall & \quad w \leq w_0 \\ \lambda(w) &= \lambda_0 \left[\frac{w}{w_0} \right]^b & \forall & \quad w > w_0 \end{aligned} \quad \text{eq. 1}$$

λ_0 ... initial constant failure rate

b ... Weibull shape parameter

w_0 ... threshold age after which the failure rate increases




Figure 1: Weibull method for modelling of ageing

Similarly, the evaluation can be done for other probability parameters than failure rate, such as failure probability.

3.1.2 Linear method

This method represents the failure rate of equipment with a function, where the failure rate is changed with age of equipment from constant failure rate before the threshold age to linear increasing failure rate after the threshold age.

Threshold can be incorporated in the mathematical formulation to represent the beginning of ageing at some nonzero age w_0 . The basic mathematical formulation of the method is presented in the equation below.

$$\begin{aligned} \lambda(w) &= \lambda_0 & \forall & \quad w \leq w_0 \\ \lambda(w) &= \lambda_0 + \alpha(w - w_0) & \forall & \quad w > w_0 \end{aligned} \quad \text{eq. 2}$$

λ_0 ... initial constant failure rate

α ... linear aging rate

w_0 ... threshold age after which the failure rate increases




Figure 2: Linear method for modelling of ageing

Similarly, the evaluation can be done for other probability parameters than failure rate, such as failure probability.

3.1.3 Exponential method

This method represents the failure rate of equipment with a function, where the failure rate is changed with age of equipment from constant failure rate before the threshold age to exponentially increasing failure rate after the threshold age.

The basic mathematical formulation of the method is presented in the equation below.

$$\begin{aligned} \lambda(w) &= \lambda_0 & \forall & \quad w \leq w_0 \\ \lambda(w) &= \lambda_0 \cdot \exp(c(w - w_0)) & \forall & \quad w > w_0 \end{aligned} \quad \text{eq. 3}$$

λ_0 ... initial constant failure rate

c ... exponential scale parameter

w_0 ... threshold age after which the failure rate increases




Figure 3: Exponential method for modelling of ageing

Similarly, the evaluation can be done for other probability parameters than failure rate, such as failure probability.

3.2 Detailed methods for modelling of ageing

More detailed methods for modelling of ageing are developed. Their use is more theoretical than practical due to lack of real data for the support of the parameters in mathematical formulations. Examples are presented in the references from [82] to [93].

3.3 Basic methods for consideration of ageing in probabilistic safety assessment

3.3.1 Method of stepwise constant failure rates

The development of a method for consideration of aging in probabilistic safety assessment follows the initiation of activities on the field of modelling and analysis of aging effects.

The standpoint for the development of this method lays in a fact that a detailed probabilistic safety assessment of a nuclear power plant exist, which does not directly include consideration of aging in its probabilistic models. In this sense, it seemed that the extension of the existing probabilistic safety assessment models with addition of aging as an independent contribution would be the easiest solution. The deficiency of such approach would be the fact that contribution of aging may not be independent from existing contribution.

Figure 4 shows the difference in modelling, if aging is considered or not.




Figure 4: Schematic modelling for consideration of aging

Stepwise constant failure rate method assumes the constant failure rates or constant failure probabilities of equipment in the determined time intervals $\{t_i, t_{i+1}\}$, and hence this failure rates or failure probabilities are determined as their average through the time of the time interval. The change of failure rates or failure probabilities changes through the selected time intervals according to the selected method for evaluation of failure rates or failure probabilities due to ageing.

At each selected time interval the average failure rates or failure probabilities are calculated for the equipment under investigation and the evaluation of the probabilistic safety assessment is performed.

An advantage of this method is that it can be used in standard probabilistic safety assessment by standard tools for performing probabilistic safety assessment. Figure 2 shows the basic principle of method.




Figure 5: Method of stepwise constant failure rates

3.3.2 Method of prioritization of ageing from results of probabilistic safety assessment

The method of assessment of ageing from results of probabilistic safety assessment is presented in reference [88], while the data are analysed also in reference [87].

The mathematical formulation bases on the data base about components ageing rates – TIRGALEX data base, which is presented in Table 1.

Table 1: TIRGALEX data base for ageing rates of equipment

Component	Ageing rate [per hour per year]
AC bus	1.0E-09
Air operated valve	4.0E-07
Battery	3.0E-07
Check valve	4.0E-09
Circuit breaker	2.0E-08
DC bus	1.0E-09
Diesel generator	3.6E-06
Motor driven pump	2.0E-07
Motor operated valve	3.6E-06
Relay	3.0E-07
Safety/relief valve	7.0E-07
Transformer	2.0E-09
Turbine driven pump	3.0E-06
Solenoid operated valve	6.7E-07

The mathematical formulation of the method is the following.

$$\Delta\lambda_i = \lambda_i - \lambda_{i0} \quad \text{eq. 4}$$

λ_{i0} ... failure rate of equipment i (no ageing considered)

λ_i ... failure rate of equipment i with ageing considered

$\Delta\lambda_i$... the increase of failure rate of equipment i due to ageing

$$\Delta q_i = q_i - q_{i0} \quad \text{eq. 5}$$

q_{i0} ... unavailability of equipment i (no ageing considered)

q_i ... unavailability of equipment i with ageing considered

Δq_i ... the increase of unavailability of equipment i due to ageing

For tested equipment:

$$\Delta q_i = \frac{1}{4} a_i \left(\frac{1}{\lambda_{i0}} - T_i \right) T_i + \frac{1}{6} a_i T_i^2 \quad \text{eq. 6}$$

a_i ... ageing rate of equipment i

T_i ... test interval of equipment i

For equipment, which is not tested:

$$\Delta q_i = \frac{1}{2} a_i t_0^2 \quad \text{eq. 7}$$

t_0 ... facility lifetime

$$\Delta CDF = \sum_i S_i \Delta q_i + \sum_{i>j} S_{ij} \Delta q_i \Delta q_j + \sum_{i>j>k} S_{ijk} \Delta q_i \Delta q_j \Delta q_k + \dots + S_{12..n} \Delta q_1 \Delta q_2 \dots \Delta q_n \quad \text{eq. 8}$$

ΔCDF ... change in core damage frequency due to ageing

S_i ... importance of equipment i

4 UPDATE OF PROBABILISTIC SAFETY ASSESSMENT MODEL FOR CONSIDERATION OF AGEING

Update of probabilistic safety assessment model for consideration of ageing can be done in two directions:

- addition of components to the models and
- changes made to existing models, changes of the probabilistic data.

4.1 Addition of components to the models

In the current probabilistic safety assessment it is possible that:

- the failures of certain structures or passive components or other equipment are not considered, because their failure probability is negligibly low, or
- the failures of certain passive components are indirectly considered within the existing models and data connected with the corresponding active components.

In other words, probabilistic safety assessment models generally does not directly include passive components, which may be susceptible to the ageing issues more than active and tested components. Therefore the models may be updated with inclusion of the passive components.

The method for selection of passive components may consider the importance results of existing probabilistic safety assessment. The equipment with higher risk importance factors may be investigated in sense if the consideration of additional passive components improves the model.

The criteria for selection of equipment, for which a consideration about the neighbouring passive components is performed, are presented in Table 2.

Table 2: Risk criteria for determining important equipment

Risk importance measures	Criteria
RRW- Risk Reduction Worth system level	>1.05
component level	>1.005
FV- Fussell -Vesely Importance system level	>0.005
component level	>0.005
RAW- Risk Achievement Worth	>2

For the identified equipment with high risk factors the method of stepwise constant failure rate or failure probability or unavailability can be used considering linear increase of failure rate or failure probability or unavailability.

$$q_i(w) = k_i(w)q_{i0} \quad \text{eq. 9}$$

$q_i(w)$... unavailability of equipment i due to ageing

q_{i0} ... unavailability of equipment i (no ageing considered)

$k_i(w)$... factor of ageing of the respective equipment i (e.g. pipelines)

4.2 Changes made to existing models

Frequencies of initiating events such as large, medium or small loss of coolant accident, steam generator turbine rupture and steam line break depends on the history of experience with the pipes. The frequencies of newer pipelines may be lower than the frequencies of older ones.

Method of stepwise constant initiating event frequency can be used considering linear increase of initiating event frequency.

$$f_{IE}(w) = k_i(w) f_{IE0} \quad \text{eq. 10}$$

$f_{IE}(w)$... initiating event IE frequency due to ageing

f_{IE0} ... initiating event IE frequency as it is in current probabilistic safety assessment

$k_i(w)$... factor of ageing of the respective equipment i (e.g. pipelines)

5 RESULTS OF SELECTED EXAMPLES

5.1 Ageing consideration for existing models - containment spray system example

The containment spray system is selected as an example. Its fault tree consists of 11 gates and 22 basic events represented by 11 parameters.

Table 3 shows data for parameters of containment spray system considering ageing contribution. Parameters of ageing connected with of common cause failures are the same as the parameters of ageing connected with the respective basic events modelling respective primary failures.

Figure 6 shows calculated basic event unavailabilities due to ageing, which depend on timely independent unavailability and ageing parameters, such as Weibull parameter b and threshold age. Unavailability of basic events connected to test and maintenance is constant through the age.

Figure 7 shows the system unavailability due to ageing, which is obtained through the fault tree evaluations specified for time intervals of 1 year. Results show the increase of system unavailability of one order of magnitude for the considered period of 15 years.

Table 3: Data for parameters of containment spray system considering ageing contribution

Identification	Weibull Parameter b	Threshold Age [y]
BE-PAR-01	1,00E+00	5,00E+00
BE-PAR-02 (CCF)	1,30E+00	7,00E+00
BE-PAR-03	3,00E+00	4,00E+00
BE-PAR-04	1,00E+00	6,00E+00
BE-PAR-05	4,00E+00	5,00E+00
BE-PAR-06	1,30E+00	7,00E+00
BE-PAR-07 (T&M)	1,00E+00	2,00E+01
BE-PAR-08	7,00E-01	4,00E+00
BE-PAR-09	4,00E+00	5,00E+00
BE-PAR-10	2,00E-01	5,00E+00
BE-PAR-11	1,70E+01	1,00E+01




Figure 6: Basic event unavailability due to ageing




Figure 7: System unavailability due to ageing

Figure 8 and Figure 9 show Fussell-Vesely importance measure for the selected basic events of the fault tree representing selected components of the system. Results show that some equipment can be non-important, if no ageing is considered, and very important if ageing is considered and vice versa.




Figure 8: Fussell-Vesely Importance due to ageing




Figure 9: Fussell-Vesely Importance due to ageing (part 2)

Figure 10 and Figure 11 show the risk decrease factor due to ageing.




Figure 10: Risk Decrease Factor due to ageing




Figure 11: Risk Decrease Factor due to ageing (part 2)

Figure 12 shows the risk increase factor due to ageing. Results show that risk factors may considerably vary depending on ageing. If the other than linear method for consideration of

ageing would be selected, the differences in risk importance measures are expected to be even higher.




Figure 12: Risk Increase Factor due to ageing

5.2 Ageing consideration for passive components in probabilistic safety assessment - containment spray system example

The containment spray system is selected as an example. Its fault tree has been changed. Two basic events representing the piping failures were added to their respective places with small piping failure probability assessed based on piping length, number of elbows and number of welds ($Q_{\text{piping0}} = Q_{\text{piping0_pipelenght}} + Q_{\text{piping0_no_elbow}} + Q_{\text{piping0_no_welds}} = 1\text{E-}6$). Factor of ageing is assessed as linear function $k_{\text{piping}}(w) = K_a \cdot w$ and $K_a = 8,76\text{e-}6/\text{year}$ is assumed and 15 years of operating time is considered.

The results show that system unavailability slightly changed from $5,059\text{E-}4$ to $5,092\text{E-}4$, which can be assumed as neglected. The risk measures connected with piping give no indication of piping importance, except of the risk increase factor ($\text{RIF}_{\text{piping}}=26$), when ageing is 15 years.

Experience shows that the most important issue for consideration of piping is that the models of piping are performed on train bases or on appropriate segments basis. If all piping of one system is simplified and considered as one component, the model is not suitable and as such not needed.

5.3 Ageing consideration - complete probabilistic safety assessment example

Complete probabilistic safety assessment of a nuclear power plant is selected as another example. The probabilistic safety assessment model is a detailed model with thousandths of gates, thousandths of basic events, hundredths of fault trees and 16 event trees with 16 initiating events.

5.3.1 Adding passive components

Systems and subsystems, which models are changed with added basic events about piping failure probability are the following: auxiliary feedwater system motor driven pump 1, pump 2, turbine driven pump, chemical volume and control system, component cooling system train A, train B, instrument air train A, train B, residual heat removal train A, train B, safety injection to cold leg 1, cold leg 2, safety injection pump 1, pump 2, containment spray injection pump 1, pump 2, service water system train A and train B.

Added basic events about piping failure probability do not change the core damage frequency and do not impact significantly other probabilistic safety assessment results ($Q_{\text{piping}_i_0}=1\text{E-}6$).

If the ageing of piping is considered, the core damage frequency changes: $Q_{\text{piping}_i_0} = 1,31\text{E-}4$ for the period between 10 and 20 years of plant operation; $k_{\text{piping}}(w)=K_a \cdot w$ is assumed; $K_a=8,76\text{E-}6/\text{year}$; 15 years of ageing is assumed as the average for the period between 10 and 20 years of plant operation. The core damage frequency changes negligibly: from $2,81\text{E-}5/\text{ry}$ to $2,88\text{E-}5/\text{ry}$, but the risk increase factor of the parameter piping becomes significant ($\text{RIF}_{\text{piping}}=1,74\text{E+}4$). Significant $\text{RIF}_{\text{piping}}$ means that the core damage frequency and thus risk may increase significantly with the increase of piping failure probability.

Figure 13 shows sensitivity of core damage frequency due to changes of the piping failure probabilities due to ageing.




Figure 13: Sensitivity of core damage frequency due to changes of the piping failure probabilities due to ageing

5.3.2 Changing existing models – initiating events only

Initiating events frequencies were changed for two groups of initiating events. The first group include initiating events: large loss of coolant accident, medium loss of coolant accident, small loss of coolant accident, steam line break and steam generator tube rupture. The second group include initiating events: interfacing system loss of coolant accident, loss of essential service water, loss of component cooling water and loss of instrument air. For the initiating events from the first group, the initiating events frequency is changed according to linear method of consideration of ageing. For the initiating events from the second group, only the assessed part of the initiating event frequency due to piping is changed according to linear method of consideration of ageing. For the initiating events from the second group, this means that the impact of ageing is negligible, because a small increase of small part of the initiating event frequency may be lower than the round up.

The resulted core damage frequency increases with increasing initiating event frequencies depending on the percentage contribution of respective initiating events to the core damage frequency.

Table 4 shows sensitivity of core damage frequency due to changes of the initiating events frequency due to ageing. Results show that the core damage frequency increases for less than 8 percents, because the contribution of selected basic events to the initial core damage frequency (without consideration of ageing) is approximately only 21%.

Table 4: Sensitivity of core damage frequency due to changes of the initiating events frequency due to ageing

	f_{IE0} [/ry]	$f_{IE(15y)}$ [/ry]	$f_{IE(25y)}$ [/ry]	$f_{IE(35y)}$ [/ry]
Large LOCA	5,00E-06	5,50E-06	6,05E-06	6,66E-06
Medium LOCA	1,38E-03	1,52E-03	1,67E-03	1,84E-03
Small LOCA	2,70E-03	2,97E-03	3,27E-03	3,59E-03
SLB	1,30E-02	1,43E-02	1,57E-02	1,73E-02
SGTR	1,82E-03	2,00E-03	2,20E-03	2,42E-03
CDF [/ry]	2,81E-05	2,88E-05	2,94E-05	3,02E-05
IE frequency increases for K i.e. for 10% per ten years.				
LOCA ... Loss of Coolant Accident; SLB ... Steam Line Break SGTR ... Steam Generator Tube Rupture; CDF ... Core Damage Frequency				

5.3.3 Adding passive components and changing existing models

Both separate considerations from previous sections are joined together and the results are obtained.

Results on Figure 14 show that core damage frequency changes up to 14%. Results show that importance measures change more than core damage frequency (Fussler-Vesely importance measure may change for more than 30%). Figure 15 shows Fussler-Vesely importance measure for selected four important components.




Figure 14: Sensitivity of core damage frequency due to ageing

The contribution of ageing of tenths of percents of the core damage frequency is smaller than the experienced change of the core damage frequency due to modifications of probabilistic safety assessment model due to plant modifications and due to procedure changes.

Figure 16 shows an example of history of probabilistic safety assessment model, which shows much larger decrease of core damage frequency, which is shown by the increase of core damage frequency due to ageing.




Figure 15: Fussel-Vesely importance measure for selected basic events




Figure 16: The history of CDF of PSA model due to changes (plant modifications and procedure changes)

Consideration of ageing does not consider changes of human reliability, which is an important issue in probabilistic safety assessments contributing to the core damage frequency in the order of tenths of percents. Neglecting the changes of human reliability due to simulator experience and due to operators experience about the plant itself may be a larger portion than the contribution of ageing is.

Uncertainties in probabilistic safety assessment are large and through the years they were reduced by intensive data collection and analysis. Insertion of ageing issues may again largely increase the uncertainties.

6 PROBLEMS CONNECTED WITH INCLUSION OF AGEING IN PROBABILISTIC SAFETY ASSESSMENT

Experience shows that the contribution of ageing into the probabilistic safety assessment is a difficult issue at the current stage of developed models and availability of data. Some facts still prevent inclusion of ageing into the probabilistic safety assessment.

- Uncertainty of data is large in probabilistic safety assessment; with inclusion of ageing the uncertainty would increase significantly.
- Conservatism of models and analyses in probabilistic safety assessment may be much larger as the contribution of ageing.
- It is very difficult to distinguish between failures due to other reasons and failures due to ageing.
- Ageing components are mostly made of many subcomponents and possibly the problems with subcomponents may cause failures of components.
- Consideration of ageing may require significant efforts and largely more complex models, and the effects to the results may not justify the invested efforts.
- Finally, one can always argue that the consideration of ageing has already been included in the existing models with assumed constant failure rates, because the constant failure rates are determined as the average values, where all failure history is taken into account, no matter if the failures are in the beginning or at the end of the component life time.

7 CONCLUSIONS

The objective of the paper is to analyze theoretical models of ageing and to provide examples of their application, which represent the standpoint for an upgrade of current probabilistic safety assessment with the direct inclusion of ageing.

The paper presents theoretical models of ageing and practical examples, which show, how the current models can be upgraded in sense to directly include the effects of ageing into the models of probabilistic safety assessment.

The most important problem is the lack of data about the effects of ageing, which would suit to the well developed and detailed models of ageing.

One may argue that ageing is already included in the models. It only isn't separated from other causes of components and systems faults.

The effects of ageing may contribute to the models and results of probabilistic safety assessment less than other important features, which are candidates for improvement of the existing probabilistic safety assessment. From this, it can be concluded, that it is reasonable, that the models and the results of probabilistic safety assessment are firstly improved considering the suggested features and then the inclusion of ageing is considered.

8 ACKNOWLEDGEMENT

The Slovenian Research Agency partly supported this research (partly research program P2-0026, partly research project V2-0376 supported together with Slovenian Nuclear Safety Administration).

9 REFERENCES

- [1] Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications, ASME RA-S-2002, ASME, 2002; Addendum A to ASME RA-S-2002, dated December 5, 2003; Addendum B to ASME RA-S-2002, dated December 30, 2005
- [2] Reactor Safety Study: An Assessment of Accident Risks in US Commercial Nuclear Power Plants, NRC, Published as WASH-1400, 1975
- [3] PRA Procedures Guide, NUREG/CR-2300, US NRC, 1982
- [4] Probabilistic Safety Analysis Procedures Guide, NUREG/CR-2815, NRC, 1985
- [5] NUREG/CR-4550, Analysis of Core Damage Frequency, US NRC, 1990
- [6] NUREG/CR-4551, Evaluation of Severe Accident Risks, US NRC, 1990
- [7] NUREG/CR-1150, Severe Accident Risks: An Assessment for Five US Nuclear Power Plants, NRC, 1989
- [8] RG 1.200, An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities, Rev. 1, US NRC, 2007
- [9] RG 1.201, Guidelines for Categorizing Structures, Systems, and Components in Nuclear Power Plants According to their Safety Significance, Rev. 1, US NRC, 2006
- [10] NUREG/CR-6813, Issues and Recommendations for Advancement of PRA Technology in Risk-Informed Decision Making, US NRC, 2003
- [11] NEI 00-04, 10 CFR 50.69 SSC Categorization Guideline, NEI, 2005
- [12] Use of Probabilistic Risk Assessment Methods in Nuclear Regulatory Activities; Final Policy Statement, 60 FR 42622, Federal Register, Volume 60, Number 158, pp. 42622-42629, August 16, 1995
- [13] Procedures for Conduction Probabilistic Safety Assessments of Nuclear Power Plants (Level 1), Safety Series No. 50-P-4, IAEA, 1992
- [14] Procedures for Conduction Probabilistic Safety Assessments of Nuclear Power Plants (Level 2), Safety Series No. 50-P-8, IAEA, 1995
- [15] Procedures for Conduction Probabilistic Safety Assessments of Nuclear Power Plants (Level 3), Safety Series No. 50-P-12, IAEA, 1996
- [16] The Role of Probabilistic Safety Assessment and Probabilistic Safety Criteria in Nuclear Power Plant Safety, Safety Series 106, IAEA, Vienna, 1992
- [17] INSAG-12, Basic Safety Principles for Nuclear Power Plants, 75-INSAG-3 Rev. 1, IAEA, Vienna, 1999
- [18] P. Samanta, I. S. Kim, T. Mankamo, W. E. Vesely, Handbook of Methods for Risk-Based Analyses of Technical Specifications, NUREG/CR-6141, US NRC, March 1995
- [19] The Use and Development of Probabilistic Safety Assessment in NEA Member Countries, NEA/CSNI/R(2002)18, 2002
- [20] PSA Applications Guide, Electric Power Research Institute, EPRI, TR-105396, 1995
- [21] IAEA-TECDOC-478, Component Reliability Data for Use in Probabilistic Safety Assessment, IAEA, 1988
- [22] M. Čepin, B. Mavko, Optimizacija intervalov nadzornega preizkušanja v jedrski elektrarni na osnovi verjetnostih varnostnih analiz, Elektrotehniški Vestnik, 1996, Vol. 63 (3), p. 179-185
- [23] M. Čepin, B. Mavko, Probabilistic Safety Assessment Improves Surveillance Requirements in Technical Specifications, Reliability Engineering and Systems Safety, 1997, Vol. 56, p. 69-77
- [24] B. Mavko, M. Čepin, Primerjava strategij preizkušanja, Elektrotehniški Vestnik, Ljubljana, 1997, Vol. 64 (2/3), p. 142-147
- [25] M. Čepin, B. Mavko, A Dynamic Fault Tree, Reliability Engineering and System, 2002, Vol. 75, No. 1, p. 83-91
- [26] M. Čepin, Optimization of Safety Equipment Outages Improves Safety, Reliability Engineering and System Safety, 2002, Vol. 77, p.71-80
- [27] M. Čepin, S. Martorell, Evaluation of Allowed Outage Time Considering a Set of Plant Configurations, Reliability Engineering and System Safety, 2002, Vol. 78, No. 3, p. 259-266
- [28] R. Jordan Cizelj, B. Mavko, I. Kljenak, Component Reliability Assessment Using Quantitative and Qualitative Data, Reliability Engineering and System Safety, 2001, Vol. 71, p. 81-95
- [29] M. Čepin, Analysis of Truncation Limit in Probabilistic Safety Assessment, Reliability Engineering and System Safety, Vol. 87 (3), p. 395-403

- [30] D. Synak, K. Rovny, M. Lukac, Ageing management of cables in Nuclear Power Plants, 31th ESREDA Seminar, November 2006
- [31] W. Weibull, A statistical distribution of wide applicability, *J Appl Mech*, 1951, 18, p. 293–297
- [32] S. D. Durham, W. J. Padgett, Cumulative damage model for system failure with application to carbon fibers and composites. *Technometrics*, 1997, 39, p. 34–44
- [33] J. B. Almeida, Application of Weibull statistics to the failure of coatings, *J Mater Process Technol*, 1999; 93, p. 257–263
- [34] K. D. Majeske, A mixture model for automobile warranty data, *Reliab Eng Syst Saf*, 2003, 81, p. 71–77
- [35] T. Bucar, M. Nagode, M. Fajdiga, Reliability approximation using finite Weibull mixture distributions, *Reliab Eng Syst Saf*, 2004, 84, p. 241–251
- [36] L. Attardi, M. Guida, G. Pulcini, A mixed-Weibull regression model for the analysis of automotive warranty data, *Reliab Eng Syst Saf*, 2005, 87, p. 265–273
- [37] W.R. Beukenkamp, R. Methorst, Ageing in transport systems: a human and technical perspective, 31th ESREDA Seminar, November 2006
- [38] J. Zhou, W. Li, J. Lu, W. Yan, Incorporating aging failure mode and multiple capacity state model of HVDC system in power system reliability assessment, *Electric Power Systems Research* 77, 2007, p. 910–916
- [39] A. Trifanov, Current Canadian activities related to Ageing management and Ageing PSA, Ageing PSA Workshop and Network Meeting, Bucharest, October 2006
- [40] IRSN contribution into JRC Network on Incorporating Aging Effects into Probabilistic Safety Assessment (APSA): Incorporating Aging effects into PSA applications, December 2004
- [41] Y. Li, Lifetime extrapolation of 650 nm InGaAlP laser diodes with or without adequate burn-in time, *Optics & Laser Technology*, In Press, Corrected Proof, Available online 7 May 2007
- [42] R. C. Gupta, R. D. Gupta, Proportional reversed hazard rate model and its applications, *Journal of Statistical Planning and Inference*, In Press, Corrected Proof, Available online 30 March 2007
- [43] F. Peres, L. Bouzaïene, J. C. Bocquet, F. Billy, A. Lannoy, P. Haïk, Anticipating aging failure using feedback data and expert judgment, *Reliability Engineering & System Safety*, Volume 92, Issue 2, February 2007, p. 200-210
- [44] E. Roos, K.-H. Herter, X. Schuler, Lifetime management for mechanical systems, structures and components in nuclear power plants, *International Journal of Pressure Vessels and Piping*, Volume 83, Issue 10, October 2006, p. 756-766
- [45] A. Picone, M. Henkel, Local scale-invariance and ageing in noisy systems, *Nuclear Physics B*, Volume 688, Issue 3, 14 June 2004, p. 217-265
- [46] C. Clarotti, A. Lannoy, Sylvie Odin and Henri Procaccia, Detection of equipment aging and determination of the efficiency of a corrective measure, *Reliability Engineering & System Safety*, Volume 84, Issue 1, April 2004, p. 57-64
- [47] C. D. Lai and M. Xie, Relative ageing for two parallel systems and related problems, *Mathematical and Computer Modelling*, Volume 38, Issues 11-13, December 2003, p. 1339-1345
- [48] P. Shevchuk, B. Galapats, V. Shevchuk, Mathematical modelling of ageing and lifetime prediction of lacquer-paint coatings in sea water, *International Journal of Engineering Science*, Volume 38, Issue 17, November 2000, p. 1869-1894
- [49] S. Moss de Oliveira, D. Alves, J. S. Sá Martins, Evolution and ageing, *Physica A: Statistical Mechanics and its Applications*, Volume 285, Issues 1-2, 15 September 2000, p. 77-100
- [50] U. Pulkkinen, K. Simola, Bayesian models and ageing indicators for analysing random changes in failure occurrence, *Reliability Engineering & System Safety*, Volume 68, Issue 3, June 2000, p. 255-268
- [51] M. Marseguerra, E. Zio, Optimizing maintenance and repair policies via a combination of genetic algorithms and Monte Carlo simulation, *Reliability Engineering & System Safety*, Volume 68, Issue 1, April 2000, p. 69-83
- [52] E. Borgonovo, M. Marseguerra, E. Zio, A Monte Carlo methodological approach to plant availability modeling with maintenance, aging and obsolescence, *Reliability Engineering & System Safety*, Volume 67, Issue 1, January 2000, p. 61-73
- [53] M. Bebbington, C. D. Lai, R. Zitikis, A flexible Weibull extension, *Reliability Engineering & System Safety*, Volume 92, Issue 6, June 2007, p. 719-726
- [54] M. Finkelstein, On statistical and information-based virtual age of degrading systems, *Reliability Engineering & System Safety*, Volume 92, Issue 5, May 2007, p. 676-681

- [55] R. E. Lillo, Note on relations between criteria for ageing, *Reliability Engineering & System Safety*, Volume 67, Issue 2, February 2000, p. 129-133
- [56] W. Li, Incorporating aging failures in power system reliability evaluation, *IEEE Transactions on Power Systems*, Volume 17, Issue 3, Aug. 2002, p. 918 – 923
- [57] M. R. Shaneyfelt, P. S. Winokur, D. M. Fleetwood, G. L. Hash, J. R. Schwank, F. W. Sexton, R. L. Pease, Impact of aging on radiation hardness [CMOS SRAMs], *IEEE Transactions on Nuclear Science*, Volume 44, Issue 6, Part 1, Dec. 1997, p. 2040 - 2047
- [58] F. J. Blom, Reactor pressure vessel embrittlement of NPP Borssele: Design lifetime and lifetime extension, *Nuclear Engineering and Design*, In Press, Corrected Proof, Available online 6 April 2007
- [59] B. T. Timofeev, G. P. Karzov, Assessment of the WWER-440/V-213 reactor condition, *International Journal of Pressure Vessels and Piping*, Volume 83, Issue 3, March 2006, p. 216-226
- [60] F. Sevini, L. Debarberis, K. Törrönen, R. Gerard, L. M. Davies, Development of the AMES network throughout the 4th and 5th EURATOM framework programmes, *International Journal of Pressure Vessels and Piping*, Volume 81, Issue 8, August 2004, p. 683-694
- [61] K. Van Ouytsel, R. De Batist, R. Schaller, An internal friction working model to advance the understanding of effects of radiation and thermal ageing on reactor pressure-vessel steels, *International Journal of Pressure Vessels and Piping*, Volume 80, Issue 5, May 2003, p. 275-284
- [62] S. Kataoka, T. Otsuka, JAPEIC's activity on aging issue related to neutron irradiation of RPV/RV materials, *International Journal of Pressure Vessels and Piping*, Volume 77, Issue 10, 15 August 2000, p. 569-574
- [63] L. Cizelj, B. Mavko, On the risk-based steam generator lifetime optimization, *Theor. appl. fract. mech.*, 1995, vol. 23, p. 129-137.
- [64] L. Cizelj, B. Mavko, P. Vencelj, Reliability of steam generator tubes with axial cracks, *J. press. vessel technol.*, 1996, vol. 118, p. 441-446
- [65] T. Dvoršek, L. Cizelj, B. Mavko, Safety and availability of steam generator tubes affected by secondary side corrosion, *Nucl. Eng. Des.*, vol. 185, p. 11-21
- [66] L. Cizelj, F. Androjna, Staranje cevi uparjalnikov v Jedrski elektrarni Krško = Aging of tubes in the Krško nuclear power plant's steam generators, *Stroj. vestn.*, 2000, vol. 46, no. 3, p. 152-161
- [67] I. Simonovski, K. F. Nilsson, L. Cizelj, The influence of crystallographic orientation on crack tip displacements of microstructurally small, kinked crack crossing the grain boundary, *Comput. mater. sci.*, 2007, vol. 39, no. 4, p. 817-828
- [68] I. Simonovski, K. F. Nilsson, L. Cizelj, Crack tip displacements of microstructurally small cracks in 316L steel and their dependence on crystallographic orientations of grains, *Fatigue fract. eng. mater. struct.*, 2007, vol. 30, no. 6, p. 463-478
- [69] Plant life management for long term operation of light water reactors, principles and guidelines, Technical reports series no. 448, International Atomic Energy Agency (IAEA), Vienna, 2006
- [70] B. R. Ellingwood, Issues related to structural aging in probabilistic risk assessment of nuclear power plants, *Reliability Engineering & System Safety*, Volume 62, Issue 3, December 1998, p. 171-183
- [71] L. Lu, J. Jiang, Analysis of on-line maintenance strategies for k-out-of-n standby safety systems, *Reliability Engineering & System Safety*, Volume 92, Issue 2, February 2007, p. 144-155
- [72] M. Marseguerra, R. Masini, E. Zio, G. Cojazzi, Variance decomposition-based sensitivity analysis via neural networks, *Reliability Engineering & System Safety*, Volume 79, Issue 2, February 2003, p. 229-238
- [73] R. Jiang, P. Ji, X. Xiao, Aging property of unimodal failure rate models, *Reliability Engineering & System Safety*, Volume 79, Issue 1, 1 January 2003, p. 113-116
- [74] T. A. Hilsmeier, T. Aldemir, W. E. Vesely, Time-dependent unavailability of aging standby components based on nuclear plant data, *Reliability Engineering & System Safety*, Volume 47, Issue 3, 1995, p. 199-205
- [75] W. Gunther, K. Sullivan, Detecting and mitigating rod drive control system degradation in Westinghouse PWRs, *IEEE Transactions on Nuclear Science*, Volume 38, Issue 6, Part 1, Dec. 1991, p. 1760 – 1765
- [76] R. Hall, W. Gunther, J. Boccio, Managing the effects of aging and reliability improvement, *Nuclear Engineering and design*, Volume 115, 1989, p. 201 - 205
- [77] J. Philips, W. Roesener, H. Magleby, V. Geidl, Incorporation of passive components aging into PRA's, *Nuclear Engineering and design*, Volume 142, 1991, p. 167 – 177
- [78] K. Simola, VTT Publications 379, Reliability Methods in Nuclear Power Plant Ageing Management, VTT, 1999

- [79] M. Patrik, C. Kirchsteiger, JRC Network on Incorporating Ageing Effects into Probabilistic Safety Assessment Applications, Proceedings of the Kick off meeting, JRC IE Report, EUR 21382 EN, Petten, October 2004
- [80] C. Atwood, O. Cronval, C. Kirchsteiger, M. Nitoi, M. Patrik, A. Rodionov, APSA in risk informed applications, living report - version January 2006
- [81] NUREG/CR-6859, PRA Procedures and Uncertainty for PTS Analysis, US NRC, 2006
- [82] NUREG/CR-5632, Incorporating Aging Effects into Probabilistic Risk Assessment — A Feasibility Study Utilizing Reliability Physics Models, US NRC, 2001
- [83] NUREG/CR-5510, Evaluations of Core Melt Frequency Effects Due to Component Aging and Maintenance, US NRC, 1990
- [84] NUREG-1864, A Pilot Probabilistic Risk Assessment Of a Dry Cask Storage System At a Nuclear Power Plant, US NRC, 2007
- [85] NUREG/CR-4769 EGG-2476, Risk Evaluations of Aging Phenomena: the Linear Aging Reliability Model and Its Extensions, US NRC, 1987
- [86] NUREG-1144, Nuclear Plant Aging Research (NPAR) Program Plan, Rev. 2, US NRC, 1991
- [87] NUREG/CR-5248, Prioritization of TIRGALEX Recommended Components for Further Aging Research, US NRC, 1988
- [88] NUREG/CR-5587, Approaches for Age-Dependent Probabilistic Safety Assessments With Emphasis on Prioritization and Sensitivity Studies, US NRC, 1992
- [89] NUREG/CR-6679, Assessment of Age-Related Degradation of Structures and Passive Components for U.S. Nuclear Power Plants, US NRC, 2000
- [90] NUREG/CR-4747, An Aging Failure Survey of Light Water-Reactor Safety Systems and Components, US NRC, 1998
- [91] NUREG/CR-5378, Aging Data Analysis and Risk Assessment Development and Demonstration Study, US NRC, 1992
- [92] R. Briš, M. Čepin, Stochastic ageing models under two kinds of failures, 31st ESReDA Seminar, Smolenice, Slovakia, November 7-8, 2006, p. 124-136
- [93] M. Čepin, R. Briš, Models of aging equipment in the probabilistic safety assessment. V: 31st ESReDA Seminar, Smolenice, Slovakia, November 7-8, 2006. Aging. Slovak Nuclear Forum: Slovak Nuclear Society, 2006, p. 165-172.
- [94] T. Banjac, M. Čepin, Consideration of Aging in Probabilistic Safety Assessment, NENE2007, 2007
- [95] K. Anandakumaran, Aging and condition monitoring studies of composite insulation cables used in nuclear power plants, IEEE Transactions on Dielectrics and Electrical Insulation, Volume 14, Issue 1, 2007, p. 227 – 237
- [96] S. Martorell, A. Sanchez and V. Serradell, Age-dependent reliability model considering effects of maintenance and working conditions, Reliability Engineering & System Safety, Volume 64, Issue 1, 1999, p. 19-31
- [97] R. Radulovich, E. Vesely , T. Aldemir, **Aging** effects on time-depended nuclear plant component unavailability: an investigation of variations from static calculations, Nuclear Reactor Safety, Volume 112, October 1995, p. 21-41
- [98] J. Blombach, K. U. Brahmstaedt, L. Camarinopoulos, Does ageing of NPPs require the incorporation of time dependent failure rates in PSA models?-Verification using operating experience of emergency diesel generators collected in ZEDB, ESReDA Seminar, Smolenice, Slovakia, November 7-8, 2006
- [99] L. Burgazzi, Incorporation of Ageing Effects into Component Reliability and Availability Models, Proceedings of ESREL2006, Safety and Reliability for Managing Risk, Vol. 3, p. 2397-2403
- [100] M. Čepin, A. Volkanovski, B. Mavko, Uporaba verjetnostnih varnostnih analiz pri obvladovanju staranja, IJS-DP-9614, 2007, p. 34-35